

Certificate

Applicant: **Steca Elektronik GmbH**
Mammostrasse 1
87700 Memmingen
Germany

Product: **Photovoltaic Inverter**

Model:

StecaGrid 4213	StecaGrid 5513	StecaGrid 7013	StecaGrid 8513	StecaGrid 10013
---------------------------	---------------------------	---------------------------	---------------------------	----------------------------

Intended use:

Automatic disconnection device with three-phase mains surveillance in accordance with VDE 0126-1-1 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

SOP-9-1_11 GCC Certification Program, 04/18

Based on:

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 17PP205-04

Certificate No: 18-263-00

Date of issue: 2018-08-14



Tanja Rottach
- Digitally signed | see <http://ca.primara.net> for more details -

Tanja Rottach
Certification Engineer

