

Certificate

Applicant: **Steca Elektronik GmbH**
Mammostraße 1
87700 Memmingen
Germany

Product: **Photovoltaic Inverter**

Modell:

Steca Grid 1511	Steca Grid 2011	Steca Grid 2511	Steca Grid 3011	Steca Grid 3011_2	Steca Grid 3611	Steca Grid 3611_2	Steca Grid 4611_2
-----------------------	-----------------------	-----------------------	-----------------------	-------------------------	-----------------------	-------------------------	-------------------------

Intended use:

Automatic disconnection device with mains surveillance in accordance with VDE 0126-1-1 for photovoltaic systems with a single-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

Applied standards and guidelines:

SOP-9-1_11 GCC Certification Program, 04/18

Based on:

DIN VDE 0126-1-1 (VDE V 0126-1-1):2013-08

Automatic disconnection device between a generator and the public low-voltage grid

The safety concept of an aforementioned representative product corresponds at the time of issue of this certificate to the valid safety specifications for the specified use in accordance with regulations.

Report No: 17PP299-06

Certificate No: 18-225-01

Date of issue: 2018-08-30



Tanja Rottach
- Digitally signed | see <http://ca.primara.net> for more details -

Tanja Rottach
Certification Engineer

